

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance**0432-CPR-00099-13**

Version 01

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Stay arm door coordinator ECO SR Basis

Door coordinators for double-leaf doors in accordance with the composition and classification in annex 2 placed on the market under the name or trade mark of

ECO Schulte GmbH & Co. KG

Iserlohner Landstraße 89
58706 Menden
Germany

and produced in the manufacturing plant(s)

DO 2.30

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1158: 1997/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 01.08.2018 and will remain valid until 01.08.2023 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 01.08.2018



By order



Dipl.-Ing. Friedrich
Head of Certification Body

This Certificate consists of 1 page and 2 annex(es).

The original of this document was issued in German language.

In case of doubt only the German version is valid.





Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Door coordinator ECO SR Basis

Manufacturing plant

Product	Manufacturing plant
Door Coordinator	DO 2.30

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

List of Products

Type :	Stay arm door coordinator ECO SR Basis
Description :	Door coordinator IS for double-leaf-doors
Size :	3 - 7
Classification :	3 5 3-7 1 1 4
Manufacturing plant :	DO 2.30
Remarks :	the carry bar „MK Basis 1“ is always required if the correct closing sequence of both door leaves is not achieved.

Intended use:

For single- and double leaf fire- and/or smoke protection doors

Essential properties	Clauses with requirements in EN 1158:1997/A1:2002/AC:2006	Performance of the product
Self-closing	5.1.2 Completeness of the products 5.1.3 Correct closing sequence 5.2.1 General 5.2.2 Overload behaviour in closing direction 5.2.3 Manipulation 5.2.4 Resistance in waiting position 5.2.6 Damage 5.2.8 Use on fire-/ smoke protection doors	Passed Passed (Size 3-7) Passed (Size 3-7) Passed (Size 3-7) Passed (Size 3-7) Passed (Size 3-7) Class 1: Passed
Durability of Self-closing	5.2.5 Durability 5.2.7 Corrosion resistance 5.2.7.1 5.2.7.2 5.2.7.3	Class 5 (50.000 Cycles): passed Class 4 (240h): passed Class 4 (240h): passed Class 4 (240h): passed
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.